



Portable Appliance Testing Report

DJ Paul Mully

Test Period Commencing

24-May-2023

Order No

Company Contact Name

Mr Paul Mulgrew

Certificate

of Electrical Appliance Testing



(Signed)...

T Blake

Birmingham PAT Testing LLP

Certificate issued by

Birmingham PAT Testing LLP
26 Longmeadow Grove
Cofton Common
Birmingham
B31 4SU
Phone: 0121 244 8789
Mobile: 07789 686 093
Email: karen@birminghampattesting.com
Web: www.birminghampattesting.com



Certificate issued to

DJ Paul Mully
12 Glentworth Avenue
Coventry
West Midlands
CV6 2HW

Appliance Register
For all Sites and Locations

DJ Paul Mully
12 Glentworth Avenue
Coventry
West Midlands
CV6 2HW



Birmingham PAT Testing LLP
26 Longmeadow Grove
Cofton Common
Birmingham
B31 4SU

Phone: 0121 244 8789

Mobile: 07789 686 093

Email: karen@birminghampattesting.com

Web: www.birminghampattesting.com

Appliance Description	Appliance Id	Test Date	ReTest Date	Status
QSC SPEAKER	1809691	24/05/23	24/05/24	PASS
SHURE POWER PACK	1809692	24/05/23	24/05/24	PASS
AC-ADAPTOR	1809693	24/05/23	24/05/24	PASS
DB TECHNOLOGIES SUBWOOFER	1809694	24/05/23	24/05/24	PASS
POWERCON LEAD	1809695	24/05/23	24/05/24	PASS
POWERCON LEAD	1809696	24/05/23	24/05/24	PASS
ADJ LIGHT	1809697	24/05/23	24/05/24	PASS
POWERCON LEAD	1809698	24/05/23	24/05/24	PASS
POWERCON LEAD	1809699	24/05/23	24/05/24	PASS
POWERCON LEAD	1809700	24/05/23	24/05/24	PASS
POWERCON LEAD	1809701	24/05/23	24/05/24	PASS
IEC LEAD	1809702	24/05/23	24/05/24	PASS
IEC LEAD	1809703	24/05/23	24/05/24	PASS
IEC LEAD	1809704	24/05/23	24/05/24	PASS
IEC LEAD	1809705	24/05/23	24/05/24	PASS
IEC LEAD	1809706	24/05/23	24/05/24	PASS
IEC LEAD	1809707	24/05/23	24/05/24	PASS
IEC LEAD	1809708	24/05/23	24/05/24	PASS
IEC LEAD	1809709	24/05/23	24/05/24	PASS
IEC LEAD	1809710	24/05/23	24/05/24	PASS
IEC LEAD	1809711	24/05/23	24/05/24	PASS
IEC LEAD	1809712	24/05/23	24/05/24	PASS
ANTARI FOG MACHINE	1809713	24/05/23	24/05/24	PASS
IEC LEAD	1809714	24/05/23	24/05/24	PASS
IEC LEAD	1809715	24/05/23	24/05/24	PASS
POWERCON LEAD	1809716	24/05/23	24/05/24	PASS
ADJ LIGHT	1809717	24/05/23	24/05/24	PASS
CHAUVET LIGHT	1809718	24/05/23	24/05/24	PASS
IEC LEAD	1809719	24/05/23	24/05/24	PASS
IEC LEAD	1809720	24/05/23	24/05/24	PASS
IEC LEAD	1809721	24/05/23	24/05/24	PASS
POWERCON LEAD	1809722	24/05/23	24/05/24	PASS
MARTIN LIGHT	1809723	24/05/23	24/05/24	PASS
MARTIN LIGHT	1809724	24/05/23	24/05/24	PASS
IEC LEAD	1809725	24/05/23	24/05/24	PASS
IEC LEAD	1809726	24/05/23	24/05/24	PASS
CHAUVET LIGHT	1809727	24/05/23	24/05/24	PASS
ADJ LIGHT	1809728	24/05/23	24/05/24	PASS
5 WAY EXTENSION LEAD	1809729	24/05/23	24/05/24	PASS
FBT SUBWOOFER	1809730	24/05/23	24/05/24	PASS
FBT SUBWOOFER	1809731	24/05/23	24/05/24	PASS
IEC LEAD	1809732	24/05/23	24/05/24	PASS
DENON POWER PACK	1809733	24/05/23	24/05/24	PASS
QSC SPEAKER	1809734	24/05/23	24/05/24	PASS
4 WAY EXTENSION LEAD	1809884	24/05/23	24/05/24	PASS
8 WAY EXTENSION LEAD	1809885	24/05/23	24/05/24	PASS
8 WAY EXTENSION LEAD	1809886	24/05/23	24/05/24	PASS
IEC LEAD	1809887	24/05/23	24/05/24	PASS
4 WAY EXTENSION LEAD	1809888	24/05/23	24/05/24	PASS
3 WAY EXTENSION LEAD	1809889	24/05/23	24/05/24	PASS
4 WAY EXTENSION LEAD	1809890	24/05/23	24/05/24	PASS
1 WAY EXTENSION LEAD	1809891	24/05/23	24/05/24	PASS
8 WAY EXTENSION LEAD	1809892	24/05/23	24/05/24	PASS
6 WAY EXTENSION LEAD	1809893	24/05/23	24/05/24	PASS
4 WAY EXTENSION LEAD	1809894	24/05/23	24/05/24	PASS

Appliance Description	Appliance Id	Test Date	ReTest Date	Status
6 WAY EXTENSION LEAD	1809895	24/05/23	24/05/24	PASS
EQUINOX HELIX LIGHT	1809896	24/05/23	24/05/24	PASS
IEC LEAD	1809897	24/05/23	24/05/24	PASS
IEC LEAD	1809898	24/05/23	24/05/24	PASS
EQUINOX HELIX LIGHT	1809899	24/05/23	24/05/24	PASS
POWERCON LEAD	1809900	24/05/23	24/05/24	PASS
ADJ LIGHT	1809901	24/05/23	24/05/24	PASS
FBT SPEAKER	1809902	24/05/23	24/05/24	PASS
FBT SPEAKER	1809903	24/05/23	24/05/24	PASS
FBT SPEAKER	1809904	24/05/23	24/05/24	PASS
FBT SPEAKER	1809905	24/05/23	24/05/24	PASS
POWER PACK	1809906	24/05/23	24/05/24	PASS
IEC LEAD	1809907	24/05/23	24/05/24	PASS

**Report Of Passed And Failed Appliances
For all Sites and Locations**

DJ Paul Mully
12 Glentworth Avenue
Coventry
West Midlands
CV6 2HW



Birmingham PAT Testing LLP
26 Longmeadow Grove
Cofton Common
Birmingham
B31 4SU

Phone: 0121 244 8789
Mobile: 07789 686 093

Email: karen@birminghampattesting.com
Web: www.birminghampattesting.com

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA	
DJ PAUL MULLY -												
QSC SPEAKER	1809691	24/05/23	P	S	0.05 P	6.40 P	S	S	S	S	S	
SHURE POWER PACK	1809692	24/05/23	P	S	S	>199 P	S	S	S	S	S	
AC-ADAPTOR	1809693	24/05/23	P	S	S	>199 P	S	S	S	S	S	
DB TECHNOLOGIES SUBWOOFER	1809694	24/05/23	P	S	0.07 P	>199 P	S	S	S	S	S	
POWERCON LEAD	1809695	24/05/23	P	S	0.04 P	>199 P	S	S	S	S	S	
POWERCON LEAD	1809696	24/05/23	P	S	0.00 P	>199 P	S	S	S	S	S	
ADJ LIGHT	1809697	24/05/23	P	S	0.06 P	>199 P	S	S	S	S	S	
POWERCON LEAD	1809698	24/05/23	P	S	0.09 P	>199 P	S	S	S	S	S	
POWERCON LEAD	1809699	24/05/23	P	S	0.18 P	>199 P	S	S	S	S	S	
POWERCON LEAD	1809700	24/05/23	P	S	0.18 P	>199 P	S	S	S	S	S	
POWERCON LEAD	1809701	24/05/23	P	S	0.13 P	>199 P	S	S	S	S	S	
IEC LEAD	1809702	24/05/23	P	P	0.10 P	>199 P	S	S	S	S	S	
IEC LEAD	1809703	24/05/23	P	P	0.17 P	>199 P	S	S	S	S	S	
IEC LEAD	1809704	24/05/23	P	P	0.10 P	>199 P	S	S	S	S	S	
IEC LEAD	1809705	24/05/23	P	P	0.10 P	>199 P	S	S	S	S	S	
IEC LEAD	1809706	24/05/23	P	P	0.24 P	>199 P	S	S	S	S	S	
IEC LEAD	1809707	24/05/23	P	P	0.16 P	>199 P	S	S	S	S	S	
IEC LEAD	1809708	24/05/23	P	P	0.14 P	>199 P	S	S	S	S	S	
IEC LEAD	1809709	24/05/23	P	P	0.16 P	>199 P	S	S	S	S	S	
IEC LEAD	1809710	24/05/23	P	P	0.11 P	>199 P	S	S	S	S	S	
IEC LEAD	1809711	24/05/23	P	P	0.14 P	>199 P	S	S	S	S	S	
IEC LEAD	1809712	24/05/23	P	P	0.07 P	>199 P	S	S	S	S	S	
ANTARI FOG MACHINE	1809713	24/05/23	P	S	0.05 P	>199 P	S	S	S	S	S	
IEC LEAD	1809714	24/05/23	P	P	0.25 P	>199 P	S	S	S	S	S	
IEC LEAD	1809715	24/05/23	P	P	0.09 P	>199 P	S	S	S	S	S	
POWERCON LEAD	1809716	24/05/23	P	S	0.13 P	>199 P	S	S	S	S	S	
ADJ LIGHT	1809717	24/05/23	P	S	0.02 P	>199 P	S	S	S	S	S	
CHAUVET LIGHT	1809718	24/05/23	P	S	0.07 P	191.00 P	S	S	S	S	S	
IEC LEAD	1809719	24/05/23	P	P	0.18 P	>199 P	S	S	S	S	S	
IEC LEAD	1809720	24/05/23	P	P	0.15 P	>199 P	S	S	S	S	S	
IEC LEAD	1809721	24/05/23	P	P	0.23 P	>199 P	S	S	S	S	S	
POWERCON LEAD	1809722	24/05/23	P	S	0.04 P	>199 P	S	S	S	S	S	
MARTIN LIGHT	1809723	24/05/23	P	S	0.16 P	>199 P	S	S	S	S	S	
MARTIN LIGHT	1809724	24/05/23	P	S	0.21 P	>199 P	S	S	S	S	S	
IEC LEAD	1809725	24/05/23	P	P	0.12 P	>199 P	S	S	S	S	S	
IEC LEAD	1809726	24/05/23	P	P	0.14 P	>199 P	S	S	S	S	S	
CHAUVET LIGHT	1809727	24/05/23	P	S	0.25 P	>199 P	S	S	S	S	S	
ADJ LIGHT	1809728	24/05/23	P	S	0.02 P	>199 P	S	S	S	S	S	
5 WAY EXTENSION LEAD	1809729	24/05/23	P	P	0.09 P	>199 P	S	S	S	S	S	
FBT SUBWOOFER	1809730	24/05/23	P	S	0.14 P	>199 P	S	S	S	S	S	
FBT SUBWOOFER	1809731	24/05/23	P	S	0.19 P	>199 P	S	S	S	S	S	
IEC LEAD	1809732	24/05/23	P	P	0.10 P	>199 P	S	S	S	S	S	
DENON POWER PACK	1809733	24/05/23	P	S	S	>199 P	S	S	S	S	S	
QSC SPEAKER	1809734	24/05/23	P	S	0.02 P	>199 P	S	S	S	S	S	
4 WAY EXTENSION LEAD	1809884	24/05/23	P	P	0.14 P	>199 P	S	S	S	S	S	
8 WAY EXTENSION LEAD	1809885	24/05/23	P	P	0.10 P	107.00 P	S	S	S	S	S	
8 WAY EXTENSION LEAD	1809886	24/05/23	P	P	0.14 P	143.00 P	S	S	S	S	S	
IEC LEAD	1809887	24/05/23	P	P	0.15 P	>199 P	S	S	S	S	S	
4 WAY EXTENSION LEAD	1809888	24/05/23	P	P	0.12 P	109.00 P	S	S	S	S	S	
3 WAY EXTENSION LEAD	1809889	24/05/23	P	P	0.06 P	157.00 P	S	S	S	S	S	
4 WAY EXTENSION LEAD	1809890	24/05/23	P	P	0.09 P	134.00 P	S	S	S	S	S	
1 WAY EXTENSION LEAD	1809891	24/05/23	P	P	0.21 P	115.00 P	S	S	S	S	S	

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
8 WAY EXTENSION LEAD	1809892	24/05/23	P	P	0.18 P	127.00 P	S	S	S	S	S
6 WAY EXTENSION LEAD	1809893	24/05/23	P	P	0.11 P	137.00 P	S	S	S	S	S
4 WAY EXTENSION LEAD	1809894	24/05/23	P	P	0.09 P	193.00 P	S	S	S	S	S
6 WAY EXTENSION LEAD	1809895	24/05/23	P	P	0.06 P	146.00 P	S	S	S	S	S
EQUINOX HELIX LIGHT	1809896	24/05/23	P	S	0.10 P	136.00 P	S	S	S	S	S
IEC LEAD	1809897	24/05/23	P	P	0.17 P	164.00 P	S	S	S	S	S
IEC LEAD	1809898	24/05/23	P	P	0.13 P	99.00 P	S	S	S	S	S
EQUINOX HELIX LIGHT	1809899	24/05/23	P	S	0.13 P	177.00 P	S	S	S	S	S
POWERCON LEAD	1809900	24/05/23	P	S	0.11 P	120.00 P	S	S	S	S	S
ADJ LIGHT	1809901	24/05/23	P	S	0.11 P	104.00 P	S	S	S	S	S
FBT SPEAKER	1809902	24/05/23	P	S	0.18 P	137.00 P	S	S	S	S	S
FBT SPEAKER	1809903	24/05/23	P	S	0.21 P	140.00 P	S	S	S	S	S
FBT SPEAKER	1809904	24/05/23	P	S	0.17 P	138.00 P	S	S	S	S	S
FBT SPEAKER	1809905	24/05/23	P	S	0.17 P	195.00 P	S	S	S	S	S
POWER PACK	1809906	24/05/23	P	S	S	161.00 P	S	S	S	S	S
IEC LEAD	1809907	24/05/23	P	S	0.12 P	155.00 P	S	S	S	S	S

Total Appliances: 68
Total Appliances For Report: 68